



China

Choose certainty.
Add value.

TEST REPORT

No. : SHAM20150300731-2

Date : May 6, 2015

Page : 1 of 3

TearStop Building Materials Co., Ltd.

No.28 Majiroad, WaiGaoQiao Free Trade Zone, Shanghai

The following sample(s) was/ were submitted and identified on behalf of the client as:

Sample Name : anticondensation felt
Sample Number : SHAM20150300731-2
Material and Mark : TEARSTOP
Test Required : Water absorption
Date of Receipt : Mar.27,2015
Test Period : Mar.27,2015~ May 5,2015

Test result(s) : For further details, please refer to the following page(s)

***** To be continued*****

Sign for

TÜV SÜD Certification and Testing (China) Co., Ltd.

Shanghai Branch

Material Lab

Reviewed by:

Xi Zhang

Xi Zhang

Senior Testing Engineer



Authorized by:

Cosmo Yuan

Cosmo Yuan

Technical Supervisor

Note: (1) General Terms & Conditions as mentioned overleaf. (2) The results exclusively relate to the sample(s) under test. (3) The test report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory:

Material Laboratory

The 3rd Building, No. 589, Quwu Road, Minhang District,
Shanghai, 200241, P.R. China

Phone: +86 21 60149880

Fax: +86 21 60149870

www.tuv-sud.cn

Regd. Office:

TÜV SÜD Certification and Testing (China) Co., Ltd.

Shanghai Branch

No.88 Heng Tong Road Shanghai 200070

P.R. China

TÜV® SHAML 0022476



China

Choose certainty.
Add value.

TEST REPORT

No. : SHAM20150300731-2

Date : May 6, 2015

Page : 2 of 3

Water absorption:

Sample description : Grey felt with glue

Test method : DIN 53923-1978

Test condition : Specimen size: 100mm×100mm

Test result:

Test item	Result
Water absorption 0°	1074g/m ²
Water absorption 45°	753g/m ²
Water absorption 90°	672g/m ²

***** To be continued*****

Note: (1) General Terms & Conditions as mentioned overleaf. (2) The results exclusively relate to the sample(s) under test. (3) The test report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory:

Material Laboratory

The 3rd Building, No. 589, Quwu Road, Minhang District,
Shanghai, 200241, P.R. China

Phone: +86 21 60149880

Fax: +86 21 60149870

www.tuv-sud.cn

Regd. Office:

TÜV SÜD Certification and Testing (China) Co., Ltd.
Shanghai Branch

No.88 Heng Tong Road Shanghai 200070
P.R. China

TÜV[®] SHAML 0022477



China

Choose certainty.
Add value.


TEST REPORT

No. : SHAM20150300731-2

Date : May 6, 2015

Page : 3 of 3

Sample photo:



***** End of report *****

Note: (1) General Terms & Conditions as mentioned overleaf. (2) The results exclusively relate to the sample(s) under test. (3) The test report shall not be reproduced except in full, without the written approval of the laboratory.

Laboratory:

Material Laboratory

The 3rd Building, No. 589, Quwu Road, Minhang District,
Shanghai, 200241, P.R. China

Phone: +86 21 60149880

Fax: +86 21 60149870

www.tuv-sud.cn

Regd. Office:

TÜV SÜD Certification and Testing (China) Co., Ltd.

Shanghai Branch

No.88 Heng Tong Road Shanghai 200070

P.R. China

TÜV® SHAML 0022478